

Sample #	Location	Fixture	Type	2018 result	2018 retest
428662	Home Ec	ec 1		4.02	<2
428663	Home Ec	ec2		<2	
428664	Home Ec	ec3		<2	
428665	Home Ec	ec4		<2	
428666	Home Ec	ec5		<2	
428667	Home Ec	ec6		3.65	<2
428668	Home Ec	ec7		<2	
428669	HS	library foun	drinking fou	<2	
428670	Elem	elem hall	drinking fou	<2	
428671	Elem	201	bubbler	<2	
428672	Elem	205	bubbler	<2	
428673	Elem	207	bubbler	<2	
428674	Elem	209	bubbler	<2	
428675	Elem	211	bubbler	<2	
428676	Elem	213	bubbler	<2	
428677	HS	156	faucet	<2	
428678	HS	154	faucet	<2	
428679	HS	152	faucet	<2	
428680	HS	nurse	faucet	<2	
428681	Elem	103	bubbler	<2	
428682	Elem	105	bubbler	<2	
428683	Elem	107	bubbler	<2	
428684	Elem	109	bubbler	<2	
428685	Elem	113	bubbler	<2	
428686	HS	art rm hall	drinking fou	<2	
428687	Kitchen	Kitchen 1	faucet	<2	
428688	Kitchen	Kitchen 2	faucet	<2	
428689	Ngym lobby	ng hall	drinking fou	<2	
428690	Ngym lobby	Concession	faucet	<2	
428691	Lunchroom	fountain	drinking fou	<2	
428692	Elem	105	faucet	<2	
428693	Elem	203	faucet	<2	
428694	Elem	111	faucet	<2	